

27 June 2016

Mr. Artemios Andreou
Deputy Chief Executive Officer
Cloudlayer8 Limited
P.O.Box 54218
Limassol
Cyprus
3722

Re: Tier III Certification of Design Documents for the Cloudlayer8 Limited – CL8 LIM Data Center, Phase 1

Dear Mr. Andreou,

Uptime Institute Professional Services is pleased to extend the Tier Certification of Design Documents for the Cloudlayer8 Limited – CL8 LIM Data Center, Phase 1. This data center fulfills Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 19 May 2014 and 24 June 2016.

This Certification supersedes the original 27 June 2016 Tier III Certification of Design Documents for Cloudlayer8 Limited – CL8 LIM Data Center, Phase 1 with 27 June 2018 expiry.

This Certification recognizes the Cloudlayer8 Limited – CL8 LIM Data Center, Phase 1 design, as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated total Phase 1 IT capacity of 80 kilowatts (kW) comprised of Server Rack Rows 1 to 4 with an IT load of 72 kW, MDA Room with an IT load of 6 kW, and the meet-me room (MMR) with an IT load of 2 kW.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier Certification of Design Documents award is valid until 27 December 2018, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



R. Lee Kirby
President